

## **Product description**

Guideline for storage and temporary storage for drip trays with regard to fire safety, occupational safety and environmental safety according to PGS 15 (publication series hazardous substances):

A storage facility must be constructed in such a way that leaked or spilled hazardous liquid is collected in a container. To this end, the collection container must have a capacity of at least 110% of the largest package. However, if 10% of the total content of the packages is more than 110% of the content of the largest package, then the collection capacity must be equal to 10% of the total content of the packages together. The collection container must be sufficiently resistant to the stored liquids.

The collection capacity only applies to liquids. Empty, uncleaned packaging does not count. The collection facility may also be realized in storage. The choice of location for the collection facility may depend on the hazardous liquids stored. Kruizinga.nl is not liable for the type of use!

Please note! Any form of modification is not allowed. If this is the case, all regulations will lapse.

## **Specifications**

Article arrangement: New Version: for 1-4 200 I drums

Walls: walls closed Top: 1000kg/m2 Colour: orange

Surface treatment: painted

Width (mm): 1460

Insertion height (mm): 100

Weight (kg) 165 Type number: 404

EAN Code (Gtin) 8719424006094

Scan the QR code for more information

Type: receptacle for drum

Material: steel

Floor: with galvanized grid Subgroup: retention basin steel

Ral colour: 2000 Length (mm): 1460 Height (mm): 525

Loading capacity (kg): 1520 Collection volume (ltr): 885

Additional specifications: StawaR approved (DE)











**Technical information** 

## **Technical information**

Productnumber: 404E-800







